

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211044
Address: 218 NW AMBERSHAM DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Shawn Hoffman	Failed	Friday, May 27, 2022

Corrective Action Required:

- | | | |
|---|------|--|
| 1 | Misc | <ul style="list-style-type: none">- Provide gutters and down spouts- Provide splash blocks- Provide sod- Sump discharge minimum 36" away from foundation- Seal top of meter can and AC disconnect- Provide spark rings at kitchen counter outlets- Seal penetration around drain garage- Label non GFCI outlet in garage- Spark rings required at bar counter outlets- Label non GFCI outlet at sump pump |
|---|------|--|

Comments: