

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20220073
Address: 3534 SE CORBIN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Shawn Hoffman	Failed	Friday, May 27, 2022

Corrective Action Required:

- | | | |
|---|--------------------------|--|
| 1 | Miscellaneous Correction | <ul style="list-style-type: none">- provide address- Obtain an irrigation permit and submit a back flow certification- Final grading and sod- Complete down spouts- Splash blocks- Driveway inspection pending- Provide landing for deck stairs- Outlet cover missing in basement- Label non GFCI outlet in basement- Seal top of meter can and A/C disconnect- Seal all exterior penetrations- Secure A/C whip 12" from disconnect- |
|---|--------------------------|--|

Comments: