

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20211352  
Address: 4824 NE JAMESTOWN DR, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Erosion Control</b>	Adam Nacke	Failed	Friday, May 27, 2022

Corrective Action Required:

1	Misc	-Maintain gravel filter and clean silt and debris from street
---	------	---

Corrective Action Required:

2	Miscellaneous Correction	5-19-22 AN field inlet in the back yard is completely blocked with trash and silt. The whole property has trash and debris in the yard that NEEDS to be cleaned up! ( clean up trash , dig out silt in front of field inlet and repair all silt fence
---	-----------------------------	---

Corrective Action Required:

3	Miscellaneous Correction	5-27-22 AN still need to grade the silt away form the field inlet because the silt is going into the basin behind the house
---	-----------------------------	---

**Comments:**