

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20220206
Address: 2750 NE DOUGLAS ST, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Khanh Nguyen	Failed	Tuesday, May 31, 2022

Corrective Action Required:

1	Misc	-Provide Fire approval -Provide gfci protection for all receptacles in the kitchen area per NEC 210.8(B). All single-phase receptacles rated 150V or less, 50 amps or less shall have ground-fault protection for personnel
---	------	--

Comments: