

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20211044
Address: 218 NW AMBERSHAM DR, LEES SUMMIT, MO 64081
Inspected On: Tuesday, May 31, 2022
Inspected By: Michael Harkins
Expiration Date: 06/30/2022

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Michael Harkins	Temporary C of O	Tuesday, May 31, 2022

Corrective Action Required:

- | | | |
|---|------|--|
| 1 | Misc | <ul style="list-style-type: none">- Provide gutters and down spouts- Provide splash blocks- Provide sod- Sump discharge minimum 36" away from foundation- Seal top of meter can and AC disconnect- OBTAIN LAWN IRRIGATION PERMIT & SUBMIT BACK-FLOW CERTIFICATION - |
|---|------|--|

: TCO EXPIRES 6/30/2022 :