

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20212956  
Address: 3101 SW ARBORTREE DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Mitchell Schwarz	Failed	Tuesday, May 31, 2022

Corrective Action Required:

1	Misc	-submit as graded plot plan -sod -check water meter at time of sod -guard rail required at front porch when more than 30" from ground 36" out -master toilet bath fan not working -remove tabs for smoke detectors to activate
---	------	---

**Comments:**