CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213817

Address: 3746 SW MARYVILLE PL, LEES SUMMIT, MO 640823744 SW MARYVILLE PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

All Rough Inspection - Patrick Schonfeldt Failed Tuesday, May 31, 2022

Residential

Corrective Action Required:

1 Misc UNIT 3746:

OK to insulate and rock

UNIT 3744:

-address floor joist overbored for DWV SE corner basement, repair per

submitted engineer letter

-seal firewall penetration SE cable basement, this requires UL approved fire

rated intumescent caulk

Comments: