

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213817

Address: 3746 SW MARYVILLE PL, LEES SUMMIT, MO 640823744 SW MARYVILLE PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|----------------------------------|--------------------|----------|-----------------------|
| Rated Assembly Inspection | Patrick Schonfeldt | Failed | Tuesday, May 31, 2022 |

Corrective Action Required:

1 Misc

UNIT 3744:

-seal firewall penetration SE cable basement, this requires UL approved fire rated intumescent caulk

Comments: