

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212837
Address: 3201 SW ARBORTREE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Wednesday, June 01, 2022

Corrective Action Required:

1 Misc

- final grade and sod
- splash blocks and sump pump discharge to extend 36" from foundation
- check water meter at time of final grade and sod
- premise identification to be properly illuminated
- guard rail at front stoop as required where more than 30" from ground 36" out
- hand rail at basement stairs

Comments: