

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20221225
Address: 1900 NE PARK RIDGE DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Khanh Nguyen	Failed	Wednesday, June 01, 2022

Corrective Action Required:

1	DCM2 ESC DEFICIENT INSTALLATION	-ON 6/1-IT WAS OBSERVED THAT ABI CONTRACTOR WAS TRACKING MUD AND DEBRIS OUT ONTO THE STREET. STREET SHALL BE CLEANED UP WITHIN TWO WORKING DAYS. MIN 3/4" GRAVEL MIN 6" DEEP SHALL BE PROVIDED AT LOT ENTRANCE. -DEFICIENT EROSION CONTROL INSTALLATION SHALL BE CORRECTED
---	---------------------------------------	---

NO FURTHER INSPECTIONS UNTIL ADEQUATE EROSION CONTROL PROVIDED.

Comments: