



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20100231, Building Permit - Commercial  
Address: 930 NW BLUE PKWY, Unit:P, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Underslab Electrical Inspection - Commercial</b>	Khanh Nguyen	Passed	Thursday, January 20, 2011

<b>Underslab Plumbing Inspection - Commercial</b>	Khanh Nguyen	Failed	Thursday, January 20, 2011
---	--------------	--------	----------------------------

Corrective Action Required  
1 MISC

-PROVIDE FLOOR DRAINS PER PLAN  
-WET-VENTING SHALL BE LIMITED TO BATH GROUP ONLY. ALL THE OTHER DRAINAGE SHALL CONNECT DOWNSTREAM OF THE WET-VENTED BATH GROUPS (ANYTHING FIXTURE/TRAP NOT WITHIN A BATH ROOM IS NOT WITHIN A BATH GROUP); OR INDIVIDUALLY VENT EACH FIXTURE  
-COMPLETE DRAINAGE CONNECTION TO STACK IN HALLWAY

**Comments:**