



May 25, 2022

Walker Custom Homes, LLC
Attn: Jason Walker & Pete Pine

Re: 1612 SW 27th Street, Lee's Summit, MO (Lot 46, Whispering Woods, 2nd Plat)

Vista Structural Engineering, LLC, was asked to address the following city inspection comment for the house being built at 1612 SW 27th St., in Lee's Summit, MO:


- **Address only one king stud being installed at entry wall.** *Our firm recommends eliminating the hinge at this location by installing three straps at each end of the header. The straps should be Simpson CS20 or CS16 (or equivalent), and should be fastened to the header and the stud directly below, in the six locations shown in the picture on the following page.*

Our firm appreciates the opportunity to serve you. If you have any questions or if you need anything further, please feel free to contact us.

Sincerely,

Vista Structural Engineering, LLC

Dennis Heier, P.E.



VISTA STRUCTURAL ENGINEERING, LLC

14718 NW DELIA STREET
PORTLAND, OREGON 97229

PHONE: 971.233.6099
VISTASTRUCTURAL.COM



VISTA STRUCTURAL ENGINEERING, LLC

14718 NW DELIA STREET
PORTLAND, OREGON 97229

- 2 -

PHONE: 971.233.6099
VISTASTRUCTURAL.COM