

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSUBD20214631  
Address: 2151 SW M150 HWY, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Erosion Sediment Control (ESC) Inspection</b>	Diana Johnson	Failed	Wednesday, June 01, 2022

Informational:

1	Misc	Erosion control measures failed. Snow melt from recent snow storms has caused muddy roads and fencing is down in some areas.
---	------	--

Corrective Action Required:

2	Misc	On 6.1.2022 Wednesday ESS failed to install erosion control measures and vast amounts of mud are blocking the street.
---	------	---

**Comments:**