

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215296
Address: 1600 SW BUCKTHORN ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Wednesday, June 01, 2022

Corrective Action Required:

1	Misc	-protect all NM within 6' of attic access -address broken truss above owners entry [more than one] letter addresses 1 break I see 3.on 2 trusses -address dryer vent length -midway strap all dwv 2" in diameter or less -missing windows bedroom 2
---	------	--

Comments: