

City of Lee's Summit

123 Main Street
City of Greater CityView, ST
123567
Ph (555) 555 - 5555
Fax (555) 555 - 5555

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20214650

Address: 415 SW JEFFERSON ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Miscellaneous Inspection	Mark Harding	Failed	Tuesday, May 17, 2022

Corrective Action Required:

1 Misc

913-424-0244 Eric called,
will provide letter on underslab plumbing to toilet.
pictures of wall that was rocked without inspection.
look at previous permit to see what was finished in the basement.
will touch base the folling week after submittals.
MARK HARDING 04/14/2022 9:46 AM

Eric is working on it.
Michael Harkins 04/20/2022 3:25 PM

Corrective Action Required:

2 Misc

- Items that need adressed :
-provide vent location for new basement bath.
-remove NM to basement bath vanity light. no box was provided open wires above ceiling.
-condinsate drain for furnace was in a trash can. extend the condinsate to the floor drain.
- label main panel.
-remove NM from box instorage area from swithc to both celing lights.

Comments: