

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20215573  
Address: 421 NW KAYLEA CT, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Shawn Hoffman	Failed	Thursday, June 02, 2022

Corrective Action Required:

- |   |                          |   |
|---|--------------------------|---|
| 1 | Miscellaneous Correction | <ul style="list-style-type: none"><li>- Missing nails in LIB garage</li><li>- Nail south west corner of garage to plan's</li><li>- Provide roof boots</li><li>- Missing window at kitchen</li><li>- Missing window at stairs</li><li>- Fire block soffit of fur out at stairs landing</li><li>- Fire block soffit at basement rec room right of storage</li><li>- Add stud under I beam basement rec room near patio door</li><li>- Security blocking at patio door</li><li>- Plans call for 4 studs under I beam both sides at bedroom 4</li><li>- Tighten anchor bolts in basement</li><li>- Missing patio door</li></ul> |
|---|--------------------------|---|

**Comments:**