

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215573
Address: 421 NW KAYLEA CT, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Shawn Hoffman	Failed	Thursday, June 02, 2022

Corrective Action Required:

1	DCM2 ESC DEFICIENT INSTALLATION	Corrections started at time of inspection. - currently moving gravel, please clean street when possible.
---	---------------------------------------	-------------------------------------------------------------------------------------------------------------

Comments: