

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20220897

Address: 1002 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811004 NW BLACK TWIG CIR, LEES SUMMIT, MO
640811006 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811008 NW BLACK TWIG CIR,
LEES SUMMIT, MO 640811000 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Commercial	Robb Popp	Passed	Thursday, June 02, 2022

Corrective Action Required:

1	Misc	main line: gravel and bed the PVC as per code and support. recall when ready
---	------	--

Comments: