

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20215064  
Address: 3713 SW MARYVILLE PL, LEES SUMMIT, MO 640823715 SW MARYVILLE PL, LEES SUMMIT, MO  
640823717 SW MARYVILLE PL, LEES SUMMIT, MO 640823711 SW MARYVILLE PL, LEES  
SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	Patrick Schonfeldt	Failed	Thursday, June 02, 2022

Corrective Action Required:  
1 Misc 6/2/22 - INSPECTION DENIED, ENGINEER LETTER REJECTED, SEE EMAIL

UNIT 3717:

- The fire rated wall separating townhouses shall be continuous from foundation to the underside of roof sheathing, fire rating shall extend the full length of wall or assembly, IRC R302.2.3

NO INSPECTION PERFORMED ON UNITS 3711, 3713, 3715

**Comments:**