

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20210263
Address: 520 NW HOPE LN, Unit:IR, LEES SUMMIT, MO 640811801 NW OBRIEN RD, LEES SUMMIT, MO
64081520 NW HOPE LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Robb Popp	Partial	Thursday, June 02, 2022

Corrective Action Required:

1 THIRD FLOOR : THE FOLLOWING AREAS ARE APPROVED :

 AREA A

 -RC CHANNEL CORRIDOR CEILIG -
 -RC CHANNEL AT UNITS AND COMMON SPACES
 3004,3005,3006,3008,3021-3025,3027,3029
 -AREA A SCREW PATTERN CORRIDOR LID TO UNIT 3022

Corrective Action Required:

2 STAIR TOWER 1 : STAIRWAY 1 # 2003

Corrective Action Required:

3 STAIR TOWER 2 : STAIRWAY 2 # 2009 AREA A

Corrective Action Required:

4 SECOND FLOOR THE FOLLOWING AREAS ARE APPROVED

 AREA A

 -RC CHANNEL AT CORRIDOR CEILIGS
 -RC CHANNEL AT UNITS AND COMMON SPACES 2004,2005,2006,2008,
 2021-20225

Corrective Action Required:

5 FOURTH FLOOR : THE FOLLOWING AREAS ARE APPROVED :

 AREA A

 -RC CHANNEL CORRIDOR CEILING TO FIRE DOORS -

 -

 - AREA A SCREW PATTERN CORRIDOR CEILING TO FIRE DOORS -

Corrective Action Required:

6 Miscellaneous
 Correction

Corrective Action Required:

7 Misc

Comments: