



**CITY OF LEE'S SUMMIT
CODES ADMINISTRATION**

220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Temporary Certificate of Occupancy

Permit #: PRCOM20100267
Address: 930 NW BLUE PKWY, Unit:E, LEES SUMMIT, MO 64086
Inspected On: Monday, January 24, 2011
Inspected By: John BornsJoe Dir
Expiration Date: 12/31/1899 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	John Borns	Temporary C of O	Monday, January 24, 2011

Corrective Action Required:

1	MISC	ACCESSIBLE COMMERCIAL RESTROOM REQUIRES: 1) NON-ABSORBENT FINISH ON RESTROOM WALL, BASE, AND FLOOR (CRACK MUST BE FILLED) 2) ADA/ANSI ACCESSIBLE SIGN
---	------	---

Occupancy Inspection - Fire	Joe Dir	Passed	Monday, January 24, 2011
------------------------------------	---------	--------	--------------------------

Corrective Action Required:

1

Comments: