

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213953
Address: 1517 SW GEORGETOWN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Failed	Friday, June 03, 2022

Corrective Action Required:

1	Miscellaneous Correction	-Fire block penetration bedroom 2 tub (see tub trap fireblock) -support ridge both ends covered porch -fur down for plumbing at basement bedroom closet and hall -provide protection plate top plate pex, DWV basement bath vanity - Fire block plenum space at RA bedroom 3 basement (seal penetrations) -address over notched floor joist for DWV, see basement den furred down, near furnace -0 pressure on gauge, must maintain 10 psi
---	--------------------------	--

Comments: