CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215373

Address: 4812 NE JAMESTOWN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Erosion Control Khanh Nguyen Failed June 3, 2022

Corrective Action Required:

1 DCM5 ESC INSP REQUESTED INSPECTION(S) DENIED DUE TO DEFICIENT EROSION CONTROL DENIED INSTALLATION. INSTALL EROSION CONTROL ALONG THE BACK SIDE OF LOT

Corrective Action Required:

2 Miscellaneous No erosion control up. Mud an silt flowing down hill to 4820 Jamestown.

Correction

Comments: