



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20100223, Building Permit - Commercial
Address: 880 NW BLUE PKWY, Unit:G, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	John Borns	Partial	Wednesday, January 26, 2011

Corrective Action Required
1 MISC

PROTECTION OF PVC PIPING FROM PENETRATION: SHIELD
PLATES LACKING AT TWO LOCATIONS POINTED-OUT.

Comments: