CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212842

Address: 1900 SW HIGHTOWN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

All Rough Inspection - Patrick Schonfeldt Failed Monday, June 06, 2022

Residential

Corrective Action Required:

1 Misc -nail straps embedded in concrete at garage portal

-provide deck ledger attachment to house per plans/code

-provide (2) 1/2" through bolts at each post/beam connection per code

-support all vertical DWV 2" or less at mid point

-address rafters at front covered porch landing on blocks

-land NM to box at master bed wall

-complete plumbing west basement den for master bed

-install basement egress window -tighten all anchor bolts basement

-fireblock between top plate and foundation wall basement bedroom and

bathroom

-address triple floor joist bored less than 2" from end of joist for electrical,

basement mech right of stair stringer

Comments: