

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215824
Address: 204 SW 3RD ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Piping Inspection - Residential	Shawn Hoffman	Failed	Monday, June 06, 2022

Corrective Action Required:

1	Misc	-Provide a gauge and pressurize with air to at least 10 PSI . For inspection. - trench depth is ok
---	------	---

Comments: