

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSUBD20201467

Address: 1425 SW WARD RD, LEES SUMMIT, MO 640811515 SW WARD RD, LEES SUMMIT, MO 640811000 SW  
WINTHROP DR, LEES SUMMIT, MO 64081930 SW SCHERER RD, LEES SUMMIT, MO  
640821401 SW WARD RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Sanitary Sewer - Vacuum</b>	Nick Lightner	Failed	Monday, June 06, 2022

Informational:

1	Misc	6-6-22 AN 10psi 4min
		D4 passed
		D3 passed
		D2 passed
		D1 passed
		A1 passed
		A2 passed
		A3 broken riser ring FAILED
		B5 leaking air FAILED
		B4 shifted rise leaking air FAILED
		B3 passed
		B2 passed
		B1 passed
		C1 passed

**Comments:**