

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211818
Address: 1528 SW GEORGETOWN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Failed	Tuesday, June 07, 2022

Corrective Action Required:

1	Misc	-resolve outstanding inspection fees -final driveway and sidewalk inspection required -final grade and sod -splash blocks -provide guardrail at front porch -install attic access covers -complete carpet install 2nd floor stairs -provide access per code to jacuzzi tub motor at master bath -install hinges and security screws back door
---	------	---

Comments: