

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212920
Address: 518 NW MAIN ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Michael Harkins	Failed	Tuesday, June 07, 2022

Corrective Action Required:

1 Misc

Owner called from 600 nw main. The dirt and excavation on the lot of 518 Nw Main has encroached into the property line and preventing from building or replacing a new fence. place grade yard according line or contact the development center to resolve the issue.
grading the lot as per approved plot plan. if this need to be changed please submit a new plot plan showing grading details. fall around the north side of the lot along the new driveway shall direct water to the west and around the read of the lot. Please communicate with the owner of 600 and or the city to resolve this issue .

Comments: