

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213808
Address: 3817 SW MARYVILLE PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Piers/Caissons Inspection - Residential	Patrick Schonfeldt	Failed	Tuesday, June 07, 2022

Corrective Action Required:

1	Misc	-STANDING WATER IN PIERS - (2) 16" X 36" PIERS PER PLANS
---	------	---

Comments: