

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20214609

Address: 934 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081936 NW BLACK TWIG CIR, LEES SUMMIT, MO
64081938 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081932 NW BLACK TWIG CIR, LEES
SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Commercial	Robb Popp	Failed	Tuesday, June 07, 2022

Informational:

1	THE FOLLOWING AREAS ARE APPROVED	- PERIMETER FOOTINGS OK TO POUR, UFER LOCATED NORTH WALL ABOUT 6' FROM WEST WALL -
---	--	---

Corrective Action Required:

2	Miscellaneous Correction	-POST ADDRESS BEFORE ANY FURTHER INSPECTIONS
---	-----------------------------	--

Comments: