

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20212128
Address: 150 NW OLDHAM PKWY, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Water Line - Fire Hydrant	Ronald Paynter	Passed	Tuesday, June 07, 2022

Informational:
1 Misc Rodriguez Mechanical relocated old fire hydrant to the new location. Thrust blocks were poured on 45 bend and fire hydrant. Asked him to add tracer wire for the new section along with utility marking tape. Also informed him on his choices for the valve riser. RP 11-4-21

Informational:
2 Misc Fire hydrant was installed and all inspections completed previously by RP.
6/7/22 ES

Comments: