

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20212066
Address: 4416 SW TANZANITE CIR, LEES SUMMIT, MO 64082
Inspected On: Tuesday, June 07, 2022
Inspected By: Patrick Schonfeldt
Expiration Date: 7/8/2022 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Temporary C of O	Tuesday, June 07, 2022

Corrective Action Required:

- | | | |
|---|------|---|
| 1 | Misc | -obtain lawn irrigation system permit
-final driveway inspection required, contact development services to schedule
-final grade and sod
-splash blocks all downspout and sump pump locations, min 36" discharge from foundation |
|---|------|---|

****OK FOR TCO, TCO EXPIRES 7/8/22****

