

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212200
Address: 4724 NE JAMESTOWN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Plot Plan Inspection	Khanh Nguyen	Failed	Tuesday, June 07, 2022

Corrective Action Required:

1	Misc	Grading is generally ok; however, provide min 6" clearance from grade to bottom of siding
---	------	---

Comments: