

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20216410
Address: 2826 SW HEARTHSTONE PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Tuesday, June 07, 2022

Corrective Action Required:

1 Misc

- uncover anchor bolt at PFH for inspection
- address hanger used for hip rafter above dining/kitchen
- cspf nailing at rear of dining address over nailed sheathing, cspf nail pattern not to plans
- seal gaps in fireblocking left of fireplace
- uncover cover front patio for inspection
- address hip rafter connect in master NW wall

Comments: