

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20214053
Address: 2020 SW HOOK RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sanitary Sewer - Air Test	Diana Johnson	Passed	Monday, May 16, 2022

Informational:

1 Misc

On 5.19.2022 I watched Redford conduct Air Test and pass MH 1-7 to MH 1-6; MH 1-6 to MH 4-1; MH 4-1 to MH 4-2; MH 1-6 to MH 1-5; and MH 1-5 to MH 3-1.

On 5.20.2022 I watched Redford conduct Air Test and pass MH 1-1 to MH 1-2; MH 1-2 to MH 1-3; MH 1-3 to MH 2-1; MH 1-3 to MH 1-4; and MH 1-4 to MH 1-5

Comments: