

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20201467

Address: 1425 SW WARD RD, LEES SUMMIT, MO 640811515 SW WARD RD, LEES SUMMIT, MO 640811000 SW
WINTHROP DR, LEES SUMMIT, MO 64081930 SW SCHERER RD, LEES SUMMIT, MO
640821401 SW WARD RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sanitary Sewer - Vacuum	Nick Lightner	Passed	Tuesday, June 07, 2022

Informational:

1 Misc

6-6-22 AN 10psi 4min

D4 passed

D3 passed

D2 passed

D1 passed

A1 passed

A2 passed

A3 broken riser ring FAILED (fixed MH and it passed)

B5 leaking air FAILED (fixed MH and it passed)

B4 shifted rise leaking air FAILED (fixed MH and it passed)

B3 passed

B2 passed

B1 passed

C1 passed

Comments: