

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSUBD20214053  
Address: 2020 SW HOOK RD, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Sanitary Sewer - Vacuum</b>	Diana Johnson	Passed	Monday, May 16, 2022

Informational:

1 Misc

On 5.19.2022 I watched Redford conduct a Vacuum test and pass for MH 1-5, MH 1-6, MH 3-1, MH 4-1, MH 4-2 and and MH 4-3

On 5/20/2022 I watched Redford Construction conduct Vacuum Test and pass for MH 1-1, MH 1-2, MH 1-3, MH 1-4, and MH 2-1

**Comments:**