CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20221788 Address: 4709 NE JAMESTOWN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspectio	in:	Inspector:	Outcome:	Date:
Erosion Control		Khanh Nguyen	Failed	Wednesday, June 08, 2022
Corrective Action Required: 1 DCM3 ESC REQUIRED 2 DAY		EROSION CONTROL REQUIRED. PROVIDE 6" THICK OF MIN 3/4" GRAVEL AT LOT ENTRANCE		
		EROSION CONTROL SHALL BE IN COMPLIANCE WITHIN TWO BUSINESS DAYS.		

Comments: