

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20215296  
Address: 1600 SW BUCKTHORN ST, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                               | Inspector:       | Outcome:  | Date:                    |
|-------------------------------------------|------------------|-----------|--------------------------|
| <b>All Rough Inspection - Residential</b> | Mitchell Schwarz | Not Ready | Wednesday, June 08, 2022 |

Corrective Action Required:

|   |      |                                                                               |
|---|------|-------------------------------------------------------------------------------|
| 1 | Misc | -address dryer vent length must comply with code section M1502.4.5 of the IRC |
|---|------|-------------------------------------------------------------------------------|

**Comments:**