## CITY OF LEE'S SUMMIT

Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816) 969-1200 FAX (816) 969-1201

## Temporary Certificate of Occupancy

Permit #: PRRES20212200

Address: 4724 NE JAMESTOWN DR, LEES SUMMIT, MO 64064

Inspected On: Wednesday, June 08, 2022

**Inspected By:** Khanh Nguyen

Expiration Date: 7/8/2022 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.** 

Inspection: Outcome: Date:

Occupancy Inspection - Khanh Nguyen Temporary C of O Wednesday, June

Codes Residential 08, 2022

Corrective Action Required:

1 Misc \*\*PROVIDE EROSION CONTROL ALONG THE BASIN OR SEED THE

DISTURBED SOIL AREA

-Final grade \*\*Provide min 6" clearance from grade to siding

-Install two 1/2" through bolts or equivalent at each deck

beam-post connection