

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212031
Address: 3045 NW THOREAU LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sidewalk Inspection	Eric Sharp	Partial	Wednesday, June 08, 2022

Corrective Action Required:

1	Misc	Sidewalk has a soft spot on south side near existing sidewalk, will need dug out and compacted. Also has standing water on north side very near property line, will need drained before pouring(both areas marked with paint). All forms are in place and aggregate is compacted outside of those 2 areas. 6/8/22 ES
---	------	---

Comments: