

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20212835
Address: 3108 SW ARBORIDGE DR, LEES SUMMIT, MO 64082
Inspected On: Friday, June 03, 2022
Inspected By: Mitchell Schwarz
Expiration Date: 7/5/2022 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Temporary C of O	Friday, June 03, 2022

Corrective Action Required:

1	Misc	TCO UNTIL 7/5/22
---	------	------------------

- Final grade and sod (submit as graded plot plan)
- splash block and sump pump discharge to extend 36" from foundation
- check water meter at time of final grade and sod