

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20215330
Address: 1752 NW CHIPMAN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Robb Popp	Passed	Wednesday, June 08, 2022

Corrective Action Required:

1	Misc	-COMPLETE ELECTRICAL -REMOVE TEMP LIGHTING -PROVIDE COVER PLATES AT OPEN BOXES
---	------	--

Comments: