

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211979
Address: 516 SE DAVID RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Failed	Wednesday, June 08, 2022

Corrective Action Required:

1	Misc	-resolve outstanding inspection fees -submit as graded plot plan for review and approval -final grade and sod -splash blocks -provide faucet/complete plumbing at kitchen sink -provide hammer arrestors at laundry -provide (2) 1/2" through bolts each post/beam connection at deck -handrail must return at stairs to basement patio -provide security screws at basement walkout door
---	------	---

Comments: