

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211980
Address: 512 SE DAVID RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Failed	Wednesday, June 08, 2022

Corrective Action Required:

1	Misc	-upload engineer report to portal concerning steel beam per 10/22/21 all rough inspection report -obtain lawn irrigation system permit -final grade and sod -submit as graded plot plan for review and approval -provide hammer arrestors at washing machine -provide breaker lockouts for hard wired appliance / hot water heater
---	------	---

Comments: