



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Temporary Certificate of Occupancy

Permit #: PRCOM20100041
Address: 400 SW LONGVIEW BLVD, Unit:125, LEES SUMMIT, MO 64081
Inspected On: Friday, January 28, 2011
Inspected By: Mark Harding
Expiration Date: 2/14/2011 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Mark Harding	Temporary C of O	Friday, January 28, 2011

Corrective Action Required:

1 MISC TCO APPROVED WITH FIRE DEPT.

Corrective Action Required:

2 P405 BATH FIXTURES - MAX HEIGHT 34"
INSTALLATION OF FIXTURES
INSTALL MIRRORS IN BATHS

Corrective Action Required:

3 MISC CHECK POWER POLES - FEEDS TO MOBILE FURNITURE- IN
CEILING AT RE-INSPECTION

Corrective Action Required:

4 MISC OK TO STOCK AND STORE FURINTURE

Comments: