

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20201467

Address: 1425 SW WARD RD, LEES SUMMIT, MO 640811515 SW WARD RD, LEES SUMMIT, MO 640811000 SW
WINTHROP DR, LEES SUMMIT, MO 64081930 SW SCHERER RD, LEES SUMMIT, MO
640821401 SW WARD RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|--------------------------------------|------------|----------|----------------------------|
| Water Line - Hydrostatic Test | Adam Nacke | Passed | Thursday, June 09, 2022 |

Informational:

1 Misc 6-7-22 AN. The water line on Winthrop terrace passed the hydrostatic test at 150 psi for 2hours

Informational:

2 Misc 6-8-22 AN the second small water main run passed the hydrostatic test 150 psi for 2 hours

Comments: