

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212850
Address: 2102 SW RUTHERFORD DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Failed	Thursday, June 09, 2022

Corrective Action Required:

1	Miscellaneous Correction	- Splash blocks - MIN 36" DISCHARGE FROM FOUNDATION - Sump discharge less than 36" away from foundation - Provide code compliant handrail at front stairs
---	-----------------------------	---

Comments: