

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20216146
Address: 1526 SW ARBOR FALLS DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Thursday, June 09, 2022

Corrective Action Required:

1 Misc

-seal gaps in fire blocking in hvac chase master bath entry
-fire block furr out right of fridge seal gaps

-address over notched joist above bottom of stairs in basement (nail to ENGINEER SPECIFICATIONS)

Comments: